

CERTIFICATE NO: TCI-PC-011-2023

CERTIFICATE FOR

PRODUCT CERTIFICATION SCHEME

Based on an audit and signed contract agreement,
TRANS CERTIFICATION & INSPECTION (TRANS),
it is hereby certified that

NAME AND ADDRESS (CERTIFICATE HOLDER)

JBF READYMIX SDN BHD
Segar Homes Building, PT 4703,
Jalan DS 3/1, Bandar Dataran Segar, Lukut,
71010 Port Dickson,
Negeri Sembilan.

NAME AND ADDRESS (MANUFACTURER)

JBF READYMIX SDN BHD (LUKUT PLANT)
Lot 4354, Kebun Jimah, Lukut
71010 Port Dickson,
Negeri Sembilan

PLANT IDENTIFICATION

JBF-05-D-01

has complied with the requirements specified in the

MS EN 206: 2016, CIS 21: 2018 and the Certification Scheme Requirement of TRANS

under the Product Certification License Scheme

Validity Period:

This certificate is valid from **(06/07/2023)** to **(05/07/2024)**

Issue 1: Certified since 06/07/2023

The validity of Certificate is subject to regular surveillance audits.

Authorised by:




MANIZA BT MAMAT
MANAGING DIRECTOR



FOR WEBSITE VIEW ONLY

Certification Mark:



BRAND: N/A

Particulars of Producer's Concrete Code	
Concrete Code	G25N
Type of concrete	Designed Concrete
Compressive strength class	C20/25
Maximum water/ cement ratio	0.62
Slump	70 ± 20 mm
Minimum cement content, kg/m ³	300
Maximum aggregate size, mm	20
Type of production	Initial Production
Type of batching plant	Dry Batching Plant (D)
Type of cement	Ordinary Portland Cement (CEM I 52.5N)
Type of admixture	Real Set 233 – Set Retarding and Water Reducing Admixture

Source of cement : Negeri Sembilan Cement Industries Sdn Bhd (PPS Reg. No.: 1151029NS0054)

Source of coarse aggregate : Hanson Quarry Product Sdn Bhd (Tanah Merah Quarry, Negeri Sembilan)

Source of fine aggregate : PD Bricks Sdn Bhd (Kuantan, Pahang)

Source of admixture : Real Point Sdn Bhd

Source of water : Underground Water

End of list

This page is not valid if it is not printed or displayed together with certificate on the front page
Page 2 of 2